



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1636	27-Oct-2003	Number 13	Issue date 1-May-2020	30-Apr-2021

Page 1 of 2

Product designation

AUSCELL, CJ Series, sealed lead acid batteries

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Olympic Batteries Pty Ltd
Cnr. Grand Junction & South Roads, WINGFIELD, SA, AUSTRALIA, 5013

Registrant

Olympic Batteries Pty Ltd
Cnr. Grand Junction & South Roads, WINGFIELD, SA, AUSTRALIA, 5013

Producer

Shenzhen Stand Power Industrial Co., Ltd
Chijiu Industrial Zone, Fuquian Road, Guanlan Town, SHENZHEN, GUANGDONG, CHINA, 518110

Conformance criteria and evaluation

The AUSCELL, CJ Series, sealed lead acid batteries have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.4, Appendix G-1987, 'Automatic fire detection and alarm systems - Control and indicating equipment'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1636	27-Oct-2003	Number 13	Issue date 1-May-2020	30-Apr-2021	

Producer's description

The AUSCELL, CJ Series, sealed lead acid batteries are for application in cyclic service with repeated charges and discharges, or standby use in which the battery is normally maintained in a charged state and discharged only when required.

The AUSCELL, CJ Series, sealed lead acid batteries are fully sealed. Unless stated otherwise by the manufacturer, the batteries are maintenance-free and can be operated and stored in any position. The batteries contain no free electrolyte, and gas generated from water electrolysis by overcharging is absorbed by the electrodes and not expelled by the battery, under normal operation.

Technical specification

The following details are a representative extract of the technical specification for the AUSCELL, CJ Series, sealed lead acid batteries and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Battery type	Nominal voltage	Rated capacity 20Hr 1.75V/Cell	Casing length	Casing width	Overall height (including terminals)	Approx. weight
CJ12-1.3	12 V	1.3 Ah	97 mm	43 mm	58 mm	0.61 kg
CJ12-7	12 V	7.0 Ah	151 mm	65 mm	101 mm	2.66 kg
CJ12-12	12 V	12.0 Ah	151 mm	98 mm	101 mm	4.00 kg
CJ12-18	12 V	18.0 Ah	181 mm	77 mm	167 mm	5.70 kg
CJ12-26	12 V	26.0 Ah	175 mm	166 mm	125 mm	8.90 kg
CJ12-33	12 V	33.0 Ah	195 mm	130 mm	180 mm	10.30 kg
CJ12-40	12 V	40.0 Ah	197 mm	165 mm	170 mm	13.70 kg
CJ12-85	12 V	85.0 Ah	305 mm	168 mm	212 mm	26.50 kg
CJ12-100	12 V	100.0 Ah	330 mm	172 mm	221 mm	31.00 kg

Capacity (25°C): refer to individual specifications from Registrant
Terminal: refer to individual specifications from Registrant
Optimum operating temperature: 20°C