



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1660	25-Mar-2004	Number 14	Issue date 1-May-2020	30-Apr-2021

Page 1 of 1

Product designation

Protector, Model A, 15NS, 8.0 Kmetric, 68°/93°C (5mm bulb), concealed Spr. Pend. (SIN PS003), SR Sprinklers

Agent/distributor

Australian Fire Supplies & Fabrication Pty Ltd
Unit 1/32 Stennett Road, INGLEBURN, NSW, AUSTRALIA, 2565

Registrant

Australian Fire Supplies & Fabrication Pty Ltd
Unit 1/32 Stennett Road, INGLEBURN, NSW, AUSTRALIA, 2565

Producer

Protector Sprinkler Ind Co., Ltd
No.3, Alley 16, Lane 228, Nan-Kang Road Section 2, LU CHU HSIANG, TAO-YUAN HSIEN, TAIWAN, 338

Conformance criteria and evaluation

The Protector, Model A, 15NS, 8.0 Kmetric, 68°/93°C (5mm bulb), concealed Spr. Pend. (SIN PS003), SR Sprinklers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories Standard UL 199, 'Automatic Fire Sprinklers for Fire Protection Service'.
2. Underwriters Laboratories - Evaluation and listing, 'UL listing'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme

