



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 1735</b>	24-Feb-2005	Number 14	Issue date 1-May-2020	30-Apr-2021

Page 1 of 2

## Product designation

**Firesafe, Model FSW-9, water type fire extinguisher**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Fire Safety Service  
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

## Registrant

Eversafe Extinguisher Australia Pty. Ltd.  
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

### Producer

Eversafe Extinguisher Australia Pty. Ltd.  
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

## Conformance criteria and evaluation

The Firesafe, Model FSW-9, water type fire extinguisher has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.2:2007, 'Portable fire extinguishers - Specific requirements for water type extinguishers'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Water type fire extinguishers are suitable for use on Class A fires.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
<b>afp - 1735</b>	24-Feb-2005	Number 14	Issue date 1-May-2020	30-Apr-2021	

## Producer's description

The Firesafe, Model FSW-9, water type fire extinguisher is designed to be used on Class A fires and where a quenching agent is required. These extinguishers have a 304 grade stainless steel body and are fitted with a controllable brass operating valve with pressure indicator. They contain 9 litres of water pressurized with air or nitrogen to 700 kPa.

The extinguisher must be recharged immediately after any use.

## Technical specification

The following details are a representative extract of the technical specification for the Firesafe, Model FSW-9, water type fire extinguisher and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

<b>Model:</b>	EAW-9
<b>Agent capacity:</b>	9.0 litres
<b>Agent type:</b>	Water
<b>Mass full:</b>	12.0 kg (approximately)
<b>Fire class:</b>	A
<b>Fire rating ('still air'):</b>	3A
<b>Discharge time:</b>	90 seconds (approximately)
<b>Standard pressure test:</b>	2.0 MPa
<b>Operating pressure:</b>	700 kPa @ 23°C +/- 2°C
<b>Dimensions:</b>	
Height:	650 mm
Diameter:	185 mm
<b>Construction:</b>	
Cylinder:	304 grade stainless steel
Valve:	Brass
Paint finish:	Polyester powder coat - Signal Red (R13)
<b>Reference number:</b>	2452-DB-2403