



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1736	24-Feb-2005	Number 14	Issue date 1-May-2020	30-Apr-2021

Page 1 of 2

Product designation

Firesafe, FSF series, foam type portable fire extinguishers

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Fire Safety Service
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

Registrant

Eversafe Extinguisher Australia Pty. Ltd.
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

Producer

Eversafe Extinguisher Australia Pty. Ltd.
465 Lytton Road, MORNINGSIDE, QLD, AUSTRALIA, 4170

Conformance criteria and evaluation

The Firesafe, FSF series, foam type portable fire extinguishers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.4:2007, 'Portable fire extinguishers - Specific requirements for foam type extinguishers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Foam type fire extinguishers are suitable for use on Class A and B fires.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1736	24-Feb-2005	Number	Issue date	30-Apr-2021	
		14	1-May-2020		

Producer's description

The Firesafe, FSF series, foam type portable fire extinguishers utilise an 'additive', mixed with water, which produces foam when discharged.

This extinguisher uses AFFF (aqueous film-forming foam) for use on Class A and B fires. The foam provides a blanket covering when utilised on flammable liquid or carbonaceous fires assisting the exclusion of oxygen and thus reducing the ability of fuel to continue burning.

Technical specification

The following details are a representative extract of the technical specification for the Firesafe, FSF series, foam type portable fire extinguishers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Model:	FSF-2	FSF-9
Agent charge:	AFFF	
Capacity:	2.0 litres	9.0 litres
Fire class:	AB	AB
Fire rating 'still air':	1A:5B:1F	3A:20B
Working pressure:	700 kPa @ 23°C +/- 2°C	
Paint finish:	Powder coat - Signal Red (R13) / blue band	
Reference number:	2451-DB-5403	2451-DB-5404